



NOTES:

1. 100mm Pavement composition to be 30mm compacted depth 7mm wearing course and 70mm compacted depth 20mm base course asphalt.
2. Footpath crossfall to match existing.
3. Crossing to be excavated to firm base as approved by Council Superintendent. Over excavation is to be reinstated with approved material such as rock or packing sand to form a level base.
4. Bluestone base to be 100mm depth of 20 MPa concrete.
5. Joints to be filled with grey mortar 20mm thick
6. Asphalt to be laid flush with Pitchers within crossover